

CHARLEVOIX COUNTY
DEPARTMENT OF BUILDING SAFETY
301 State Street, Suite #5
Charlevoix Mi. 49720
Phone # 231-547-7236 Fax # 231-547-7250
Website: www.charlevoixcounty.org
Office hours: 7:00 am to 4:00 pm Monday -Thursday
e-mail: hiltonr@charlevoixcounty.org

Gas pressure test affidavit
Must be submitted prior to inspection.
Please print the following information.

Permit number: _____

Job site address: _____

Contractors name: _____

License number: _____

Date of test: _____

Time of test: _____

Print name of test person

Signature of test person

Date

Gas piping shall be pressure tested for a minimum of ten minutes at a minimum of three psi with no leakage or loss of pressure. Sections G2417.4.1 (406.4.1) and G2417.4.2 (406.4.2).