

CHARLEVOIX COUNTY
DEPARTMENT OF BUILDING SAFETY
301 State Street, Suite #5
Charlevoix Mi. 49720
Phone # 231-547-7236 Fax # 231-547-7250
Website: www.charlevoixcounty.org
Office hours: 7:00 am to 4:00 pm Monday -Thursday
e-mail: hiltonr@charlevoixcounty.org

Drainage and vent test affidavit.

Check one below.

Air: _____ Water: _____

Please print the following information.

Permit number: _____

Job site address: _____

Contractors name: _____

License number: _____

Date of test: _____

Time of test: _____

Print name of test person

Signature of test person

Date

Section 312.2, 312.3 and P2503.5.1. Air test 5 psi for 15 minutes. Water test 15 minutes with no less than 10-foot head of water on system.